

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

Issue No. 638

Dated: 08-5-2023


It is certified that an inspection team headed by Mr. R.K. Gupta Assistant Engineer (Name of the officer with designation) from Public Health Engineering Department Sub Division Barwani (Department/Office) inspected the Vidyodaya International School at survey No. 47/1 Village Kasthali ,Gopalpura ,Tehsil- Manawar, Dist Dhar (Name & Address of the school) on_02-05-2023 and found that the Vidyodaya International School (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of 3 Years.

Signature with Seal : 
Assistant Engineer
P.H.E. Sub-Dn., Barwani


Manager
Vidyodaya International School
Manawar
CBSE Aff. 1030936

Designation : Assistant Engineer
Public Health Engineering
Sub Div. Barwani


Principal
Vidyodaya International School
Manawar
CBSE Aff. 1030936

To
Vidyodaya International School
Survey No. 47/1 Patwari Halka No.
Village Kasthali Gopalpura
Tehsil Manawar Dist Dhar
(Name of Address of the Institutions)

**DISTRIC LABORATERY
PUBLIC HEALTH ENGGINEERING DEPARTMENT
SUB DIVISION BARWANI M. P.**

WATER ANALYSIS REPORTS

Source of sample- Vidyodaya International School Manawar dist. Dhar

PARTICULARS OF SENDER -

DISTT. BARWANI

Reference No. 289 & Date 01.05.2023

PARTICULARS OF SAMPLE

Collected/Not collected by PHED

	Sample No.	Place of Collection and details of Sample	Date
1	1	R.O. water sample	02-05-23

PARTICULARS OF BE FILLED IN THE LABORATORY


DATE OF RECEIPT :

Tested on :- 02-03/05.2023

LAB. REFERENCE NO. :

No.	Characteristics	Unit	As Per BIS - 10500:2012		Results sample No.1
			Requirement (Desirable Limit)	Permissible Limit in the absence of	
PHYSICAL TEST					
1	Temperature	oC	31.2
2	Turbidity	NTU	1	5	1.2
3	Colour	Hazen Units	5	15	-
4	Odour	Unobjectionable	objectionable	-
CHEMICAL TESTS					
5	PH	PH scale	6.5 to 8.5	No Relaxation	7.10
6	Total Hardness as Caco3	mg/l	300	600	185
7	Calcium as Ca	mg/l	75	200	65
8	Magnesium as Mg	mg/l	30	100	28
9	Total Alkanity as Caco3	mg/l	200	600	172
10	chloride as CL	mg/l	250	1000	56
11	Nitrate as NO3	mg/l	45	45	-
12	T.D.S.	mg/l	500	2000	250
13	Iron	mg/l	1	1	0.02
14	Sulphate	mg/l	200	400	15
15	Fluoride	mg/l	1	1.5	0.42
16	Manganese.as	mg/l	0.1	0.3	-
17	conductivity	mg/l	500	2000	523
18	residual Chlorine as	mg/l	0.2	1	-
BACTERIOLOGICAL TEST					
1	Total Coliform	par/100ml			Nil


Lab Assistant Signature
P.H.E. Sub Dn. Barwani


Laboratory Chemist
District Laboratory
P.H.E. Sub Dn. Barwani


Manager
Vidyodaya International School
Manawar
CBSE Aff 1030936


Principal
Vidyodaya International School
Manawar
CBSE Aff 1030936